



STATE OF MARYLAND

DEPARTMENT OF STATE POLICE

OFFICE OF THE STATE FIRE MARSHAL



Larry Hogan
Governor

Boyd K. Rutherford
Lt. Governor

1201 Reisterstown Road/C Building
Pikesville, MD 21208
410-653-8980
Fax 410-653-8988
Toll Free 800-525-3124

Colonel William M. Palozzi
Secretary

Brian S. Geraci
State Fire Marshal

July 29, 2019

To Whom It May Concern:

This letter is to confirm that the Office of the State Fire Marshal of the State of Maryland has reviewed the materials and design of the product known as *Campus Canopies* and finds them to be in compliance with the National Fire Protection Association (NFPA) standards for residence halls in colleges and universities.

The fabrics used in the *Campus Canopies* curtain panels have been manufactured to meet the flame-retardant standard of NFPA 701: Standard Methods of Fire Tests for Flame Propagation of Textiles and Films.

The canopy structure has no top and has been designed to a height that meets the sprinkler pattern development requirement of NFPA 13: Standard for the Installation of Sprinkler Systems.

Please see the attached test results from Schneider Textile Finishing in Dallas TX for additional information on *Campus Canopies'* adherence to the NFPA 701 standard, and the Expert Opinion from the National Fire Sprinkler Association for *Campus Canopies'* compliance with the NFPA 13 standard.

The Office of the State Fire Marshal shares your mission of ensuring the safety and well-being of the students, faculty, and administrators on your campus.

Please do not hesitate to contact my office if you have questions or concerns about the *Campus Canopies* privacy product.

Sincerely,

Brian S Geraci
State Fire Marshal