



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

ORLENE HAWKS
DIRECTOR

September 13, 2019

To Whom It May Concern:

This letter is to confirm that the State Fire Marshal of Michigan has reviewed the materials and design of the product known as *Campus Canopies* and finds them to be in compliance with the National Fire Protection Association (NFPA) standards for residence halls in colleges and universities.

The canopy structure has no top and has been designed to a height that meets the sprinkler pattern development required of NFPA 13: Standard for the Installation of Sprinkler Systems.

The fabrics used in the *Campus Canopies* curtain panels have been manufactured to meet the flame-retardant standard of NFPA 701: Standard Methods of Fire Tests for Flame Propagation of Textiles and Films.

Please see the test results from Schneider Textile Finishing in Dallas, Texas for additional information on *Campus Canopies'* adherence to the NFPA 701 standard, and the Expert Opinion from the National Fire Sprinkler Association for *Campus Canopies'* compliance with the NFPA 13 standard.

The Office of the State Fire Marshal shares your mission of ensuring safety and the well-being of the students, faculty, and administrators on your campus.

Please do not hesitate to contact my office if you have questions or concerns about the *Campus Canopies* privacy product.

Sincerely,

Kevin J. Sehlmeier
State Fire Marshal
Director, Bureau of Fire Services